

UL International (UK) Ltd

An affiliate of Underwriters Laboratories Inc.



**Underwriters
Laboratories.**

EC – CERTIFICATE OF CONFORMITY

0843 – CPD – 0100

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

HILTI Firestop foam CFS-F FX

Penetration Seal Classified for up to EI120 for use in flexible walls, solid walls and solid floors.

Two component firestop foam used to reinstate the fire resistance performance of wall and floor constructions, where they have been provided with apertures for the penetration of services. HILTI Firestop foam CFS-F FX may be used to provide a penetration seal with the following services: Blank seal, Cable / Cable trays, Conduits, Metal pipes, Plastic pipes and mixed services.

placed on the market by

**HILTI Corporation
Feldkircherstrasse 100
9494 Schaan
Liechtenstein**

and produced in the factory

HILTI Werk 4a

is submitted by the manufacturer to a Factory Production Control and that the approved body SINTEF Building and Infrastructure NB1071, has performed the Initial Type-Testing for the relevant characteristics of the product, the Initial Inspection of the factory and of the Factory Production Control. UL International (UK) Ltd, Notified Body 0843 performs the continuous surveillance, assessment and approval of the Factory Production Control.

This certificate attests that all provisions concerning the attestation of conformity described in European Technical Approval:

ETA-10/0109

were applied and that the product fulfils all the prescribed attestation of conformity requirements.

This certificate was first issued on 2nd July 2010 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

First issue date: 2nd July 2010

Signature:

Karl Harland
for
UL International (UK) Ltd.

